



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Unscreened Class E / Category 6 Six Connector Channel

**Brand-Rex Limited
Viewfield Industrial Estate, Glenrothes
Fife KY6 2RS, Scotland**

Attestation of Conformity No. 103392

This type of Class E / Category 6 unscreened six connector channel has been tested by 3P Third Party Testing and complies with the Class E channel requirements of 2nd Edition ISO/IEC 11801 and CENELEC EN 50173-1, and the Category 6 channel requirements of ANSI/TIA/EIA-568-B.2-1. The Attestation of Conformity is valid for the actually tested channel sample in T568B designation and consisting of the following components:

<i>Cables from Brand-Rex:</i>	<i>Horizontal Cable, Flexible Cable, Qualification Status:</i>	<i>P/N C6U, P/N C6U-HF1 and P/N C6U-HF3 P/N C6U-P24 and C6U-P24-HF1 3P Verified</i>
<i>Conn. Hardw. from Brand-Rex:</i>	<i>Snap in Jack, Patch Panel, Qualification Status:</i>	<i>P/N C6C-JAK-U-01-2 rev E having PCB Marking BRAND-REX 4002 10208 Rev 1 P/N C6C-PNL-U-24-01-2M rev E having PCB Marking 4302 10213 Rev 1a Manufacturer Verified</i>
<i>Patch Cords from Brand-Rex:</i>	<i>Patch Cords, Qualification Status:</i>	<i>P/N C6C-PC-U-020-888 and P/N C6C-PC-U-030-888 Manufacturer Verified</i>

Hoersholm, 13 November 2003

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 13 November 2003

Poul Villien

Poul Villien
Coordinating Manager