



# Attestation of Conformity

## ISO/IEC, EN & TIA/EIA Screened Class E<sub>A</sub> / Category 6A Two Connector Permanent Link

**Brand-Rex Limited**  
**Viewfield Industrial Estate, Glenrothes**  
**Fife KY6 2RS, Scotland**

### *Attestation of Conformity No. 108581*

*This type of Class E<sub>A</sub> / Category 6A screened two connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E<sub>A</sub> requirements of amendment 2 to 2<sup>nd</sup> Edition ISO/IEC 11801 (Draft 25N 1513) and Category 6A requirements of ANSI/TIA/EIA-568-B.2-10. The Attestation of Conformity is only valid for the actually tested permanent link samples in T568B configuration and consisting of the following Brand-Rex components:*

<i>Cables:</i>	<i>Horizontal Cable,</i>	<i>P/N AC6U/FTP-HF1</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardw.:</i>	<i>Keystone Jack,</i>	<i>P/N AC6JAKS000CR</i>
	<i>Qualification Status:</i>	<i>having PCB Marking M 25</i>
		<i>Manufacturer Verified</i>
<i>RJ 45 Plugs:</i>	<i>From cord,</i>	<i>P/N AC6-DCZ CP</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 9<sup>th</sup> October 2008

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 9<sup>th</sup> October 2008

*Paul Villien*

Poul Villien  
Coordinating Manager