



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Screened Class E_A / Category 6A Four Connector Channel

**Brand-Rex Limited
Viewfield Industrial Estate, Glenrothes
Fife KY6 2RS, Scotland**

Attestation of Conformity No. 108582

This type of Class E_A / Category 6A screened four connector channel has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E_A requirements of amendment 1 to 2nd Edition ISO/IEC 11801, amendment 2 to 2nd Edition ISO/IEC 11801 (Draft 25N 1513), and amendment 1 to CENELEC EN 50173-1:2007 (Draft EN 50173-1 prAA June 2008), and Category 6A requirements of ANSI/TIA/EIA-568-B.2-10. The Attestation of Conformity is only valid for the actually tested channel samples in T568B configuration and consisting of the following Brand-Rex components:

<i>Cables:</i>	<i>Horizontal Cable, Flexible Cables from Cords, Qualification Status:</i>	<i>P/N AC6U/FTP-HF1 P/N AC6PCG030 and P/N AC6-DCZ CP Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Keystone Jack, Qualification Status:</i>	<i>P/N A6CJAKS000CR having PCB Marking M 25 Manufacturer Verified</i>
<i>Cords:</i>	<i>2,0 m Equipment Cord, 2,4 m Consolidation Cord Qualification Status:</i>	<i>P/N AC6PCG030 P/N AC6-DCZ CP Manufacturer Verified</i>

Hoersholm, 14 October 2008

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 14 October 2008

Poul Villien

Poul Villien
Coordinating Manager