



Attestation of Conformity

Unscreened Category 6A TIA Connecting Hardware

Brand-Rex Identification, P/N AC6JAKU002

**Category 6A, Unscreened, Modular Jack
Electrical Transmission Performance**

**Brand-Rex Limited
Viewfield Industrial Estate, Glenrothes
Fife KY6 2RS, Scotland**

Attestation of Conformity No. 110698

This Unscreened TIA Connecting Hardware having board identification "Brand-Rex 2007 10G+ 10241 Rev3 2707" has been tested by 3P Third Party Testing and complies with the Category 6A transmission requirements of ANSI/TIA Generic Cabling Standard 568-C.2 and IEC 60512-27-100 (draft 48B/2060/CD). The requirements are passed using the complete specified re-embedded range of RJ 45 plug vectors and with the modular jacks mounted in Brand-Rex panels, P/N MMCPNLX24SIJ2M-B, for the alien crosstalk measurements. The Attestation of Conformity is valid for the actually tested connecting hardware samples and no verification of the running production is performed.

Hoersholm, 24th March 2010

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 24th March 2010

Paul Villien

Poul Villien
Coordinating Manager