



# Attestation of Conformity

## ISO/IEC, EN & TIA/EIA Screened Class E<sub>A</sub> / Category 6A Three Connector Permanent Link

**Brand-Rex Limited**  
**Viewfield Industrial Estate, Glenrothes**  
**Fife KY6 2RS, Scotland**

### *Attestation of Conformity No. 111744*

*This type of Class E<sub>A</sub> / Category 6A screened three connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E<sub>A</sub> requirements of amendments 1 and 2 to 2<sup>nd</sup> Edition ISO/IEC 11801, amendment 1 to CENELEC EN 50173-1:2009, amendment 2 to CENELEC EN 50173-1 (Draft FprAB July 2010), and Category 6A requirements of ANSI/TIA-568-C.2. The Attestation of Conformity is only valid for the actually tested permanent link samples in T568B configuration connected with RJ 45 plugs from Brand-Rex cord, P/N AC6PCG050, and consisting of the following Brand-Rex components:*

<i>Cables:</i>	<i>Horizontal Cable, Flexible Cable, Qualification Status:</i>	<i>P/N AC6U/FTP-HF1 P/N AC6-DCZ 3P Verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jack,  Qualification Status:</i>	<i>P/N AC6JAKS000 rev D having PCB marking Brand-Rex 2010 11868 Rev2 0810 Manufacturer Verified</i>
<i>Consolidation Cord:</i>	<i>With 5,0 m Flexible Cable, Qualification Status:</i>	<i>P/N AC6CPG050 HBS Manufacturer Verified</i>

Hoersholm, 10<sup>th</sup> June 2011

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 10<sup>th</sup> June 2011

*Paul Villien*

Poul Villien  
Coordinating Manager