



We help ideas meet the real world



Compliance Statement

No. 2010-160

Screened Channel, Class E_A

Channel for data centers. Maximum length of channel 67 m

Company

Brand-Rex Ltd
Viewfield Industrial Estate
Glenrothes,
Fife KY6 2 RS
United Kingdom

Channel Identification (4 connector model)

Horizontal cable: AC6-DCZ U/STP cable

Connecting hardware: AC6JAKS000 Rev A

Patch cords: AC6PCG050-888HB Rev A
AC6CPG020-808-HBS

Generic cabling standards, cabling components standard

- ISO/IEC 11801 2nd edition:2002
- ISO/IEC 11801 amendment 1:2008
- EN 50173:2007
- ANSI/TIA-568-C.2

Technical report

DELTA-N312769-05, DANAK-19J2279

Manufacturer code

2279

Certificate valid until

15 August 2011

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 15 July 2010

Erik Bech
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.delta.dk/cable



TEST Reg. no. 19