

Certificate



Aktiengesellschaft

No. z2392a-10-E

Customer:

Brand-Rex Ltd
Viewfield Industrial Estate, Glenrothes, Fife
KY6 2RS United Kingdom

Test sample(s):

- Connector:
Augmented Category 6 Shielded Tool-Free Jack
Part No.: AC6JAKS000

Applied standard(s):

- ISO/IEC 11801 AMD2 (2010-04)
- IEC 60603-7-51 Ed. 1 (IEC 48B/1977/CDV, 2008-12)

Results:

Up to a bandwidth of **500 MHz** the sample meet the **Category 6_A** limits of the specified standards and regulations.

Connector, Category 6_A

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, no. **P2392a-10-E**, from **July 09th, 2010** and shall only be applicable in conjunction with the test report.

Bexbach, July 09th, 2010

Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 – 0
Fax: +49 (0) 68 26 / 92 28 – 99
Email: info@ghmt.de